

## Ročný protokol emisných hodnôt pre RP za :

2013

Palivo		Bez TAP				Spolustaľovanie TAP				
ZL	SPH - 30 min	CO	NO <sub>x</sub>	SO <sub>2</sub>	TZL	CO	NO <sub>x</sub>	SO <sub>2</sub>	TZL	TOC
EL	[mg/Nm <sup>3</sup> ]	-	1300	400	50	-	800	50	30	30
I	[%EL]	10	20	20	30	10	20	20	30	30
N SPH > 2 EL+I		-	0	0	0	-	-	-	-	-
N PDH > EL+I		-	0	0	1	-	33	5	0	0
mesiace s % < 95% (%SPH < 1.2EL+I)		-	-	-	-	-	-	-	-	-
N F PDH		3	3	3	2	3	3	4	1	1
% (F) z N <sub>stabil</sub> (≤5%) / Účinnosť AMS		3,33 / 96,67	3,33 / 96,67	3,33 / 96,67	1,67 / 98,33	1,82 / 98,18	1,82 / 98,18	2,22 / 97,78	0,90 / 99,10	1,01 / 98,99
c - priem. hm. koncent. ZL ≤ EL [mg/m <sub>ns</sub> <sup>3</sup> ]		43.7	797.4	12.5	2.1	54.0	516.6	14.3	1.9	2.1
množstvo ZL ≤ EL [kg]		1,278.0	23,303.2	364.2	62.1	55,247.7	438,757.9	14,092.9	1,989.9	2,173.6
Q Spalin ≤ EL [tis. m <sup>3</sup> ]		29,224	29,224	29,224	28,903	1,022,914	849,329	988,558	1,022,914	1,022,914
c - priem. hm. koncent. ZL > EL [mg/m <sub>ns</sub> <sup>3</sup> ]		0.0	0.0	0.0	61.1	-	516.7	72.3	0.0	0.0
množstvo ZL > EL [kg]		0.0	0.0	0.0	19.6	-	89,697.9	2,484.0	0.0	0.0
Q Spalin > EL [tis. m <sup>3</sup> ]		0	0	0	321	-	173,585	34,355	0	0

Počet hodín za rok: 2474.5						Priemerné mesačné emisné hodnoty [mg/Nm <sup>3</sup> ]				Priemerné mesačné emisné hodnoty [mg/Nm <sup>3</sup> ]				
Stav:	Bez	Ust	Náb	ZmQ	Odst	Meranie bez TAP				Meranie so spolustaľovaním TAP				
Deň	-	""	N	Q	Z	CO	NO <sub>x</sub>	SO <sub>2</sub>	TZL	CO	NO <sub>x</sub>	SO <sub>2</sub>	TZL	TOC
Jan-13	1488.	0/0	0.	0.	0.									
Feb-13	1344.	0/0	0.	0.	0.									
Mar-13	907.	0/295	0.	286.	0.					106.3	823.1	21.6	6.6	1.3
Apr-13	1440.	0/0	0.	0.	0.									
May-13	578.	1/400	0.	509.	0.	102.9	539.3	8.3	1.0	98.9	713.9	14.7	2.0	2.7
Jun-13	612.	0/350	0.	478.	0.					67.9	813.5	13.9	1.9	2.9
Jul-13	610.	40/500	0.	338.	0.	45.6	1,021.8	12.5	1.5	102.8	741.7	15.3	1.9	5.4
Aug-13	602.	17/407	0.	462.	0.	50.3	1,084.1	15.4	1.8	93.1	781.2	19.1	2.4	2.9
Sep-13	135.	65/1 017	0.	223.	0.	45.0	1,039.5	15.1	2.1	55.2	756.6	22.6	2.9	2.6
Oct-13	463.	11/772	0.	242.	0.	56.1	801.9	31.6	3.2	63.7	722.4	25.1	2.2	2.6
Nov-13	883.	24/458	0.	75.	0.	157.2	856.9	2.5	10.3	80.0	724.9	17.2	2.5	4.0
Dec-13	798.	22/570	0.	98.	0.	59.9	739.8	38.2	29.3	49.1	701.6	47.2	4.1	3.7
<b>SUMA</b>	<b>9860.</b>	<b>180/4 769</b>	<b>0.</b>	<b>2711.</b>	<b>0.</b>	<b>73.9</b>	<b>869.0</b>	<b>17.7</b>	<b>7.0</b>	<b>79.7</b>	<b>753.2</b>	<b>21.8</b>	<b>2.9</b>	<b>3.1</b>

Meranie bez TAP	
EL je dodržaný, ak v kalend. roku:	žiadna SPH neprekročí hodnotu 2*EL+I
	žiadna PDH neprekročí hodnotu EL+I
	najmenej 95 % zo všetkých SPH za kalend. mesiac neprekročí 1,2 EL+I

Meranie s TAP	
EL je dodržaný, ak v kalend. roku:	žiadna PDH neprekročí hodnotu EL